



RE: Manufacturer's Certification,  
Blue AWWA C900-16 Pressure Main

To Whom It May Concern:

In response to your request for Manufacturer's Certificate of Compliance for potable water pipe, please be informed that Diamond 4" thru 60" CI dimension PVC pipe bears the mark NSF-61. Diamond sizes 4" through 12" also meet the requirements of NSF-14. Most of the products have certification to Underwriters Laboratory (UL) listing #76E4 and CSA B137.3. Diamond CI dimension PVC potable water pipe is manufactured and tested to meet all the requirements of AWWA C900-16. Every piece of pipe is hydrostatically tested to twice the rated pressure for 5 seconds according to the requirements of AWWA C900-16. All applicable testing is conducted in accordance with ASTM D1598, ASTM D1599, ASTM D2152, and ASTM D2412. Integral bell elastomeric sealed couplings meet the requirements of ASTM D3139, and the gaskets meet the requirements of ASTM F477.

If we may be of further assistance in this matter, please do not hesitate to call us. For your convenience, please use our toll-free phone 1-800-PVC-PIPE (1-800-782-7473.)

Sincerely,

**DIAMOND PLASTICS CORPORATION**