



Re: Manufacturer's Certification,  
ASTM D2241 IPS pipe

To Whom It May Concern:

In response to your request for Manufacturer's Certification of Compliance for potable water pipe, please be informed that Diamond 2", 3", 4", 6", 8", 10", and 12" IPS dimension SDR 41, 32.5, 26, 21, 17, and 13.5 PVC pipe bearing the mark of NSF was manufactured from compound per ASTM D1784 in accordance with the dimension and performance requirements of ASTM D2241. All applicable tests are conducted in accordance with supporting standards including ASTM D1599, ASTM D2152 and ASTM D3139. The gaskets meet the requirements of ASTM F477.

If we may be of further assistance in this matter, you may contact me at the Grand Island office at 308-385-4333

Sincerely,

**DIAMOND PLASTICS CORPORATION**