




Trans-21 14"-60"
TM



AWWA C900 CERTIFICATION

ToWhomItMayConcern:

In response to your request for Manufacturer's Certificate of Compliance for water pipe, please be informed that Diamond CIOD PVC water pipe meets all the physical, dimensional, and performance requirements of AWWA C900-16. Each and every length of pipe is hydrostatically proof tested in accordance with Section 4.3.3.3 of AWWA C900-16, ASTM D1598, and (quick burst) ASTM D1599. Quality of extrusion is tested in accordance with ASTM D2152, and ASTM D2412. Integral bell elastomeric sealed couplings are formed using Rieber technology and meet the requirements of ASTM D3139, and the gaskets meet the requirements of ASTM F477.

If we may be of further assistance in this matter, you may contact us at the Grand Island office.

Sincerely,

DIAMOND PLASTICS CORPORATION



Corporate Headquarters • 1212 Johnstown Road • P.O. Box 1608 • Grand Island, NE 68802-1608

PVC PIPE FOR THE 21st CENTURY